



PTC 15.17A Winters Chapel Road Mill, Overlay and Pedestrian Crossing

ADDENDUM #1

The following changes, additions or deletions shall be made to the following document(s); all other conditions remain the same. Each Bidder shall be responsible for ascertaining, prior to submitting a Bid, that they have received all issued Addenda.

QUESTIONS

- 1) There is a note on Drawing 05-0001 that states "Areas of Distressed Pavement should be Patched." In which items should the contractor include the cost of the asphalt patching? We suggest including an asphalt patching item on the bid schedule of items to cover this eventual work.

Response: Asphalt Patching has been added as a bid item. Sheet 06-0001 and the Bid Form within the Invitation to Bid has been revised and is attached. Included in the Bid Form is a place to provide the expected unit cost of asphalt patching and will not be included in the bidder's total bid.

- 2) Based on the typical section and the mainline drawings, it seems that the variable milling will be over 2,700 SY (over 24,300 SF). However, the bid schedule of items only includes 2,906 SF. Please confirm the unit or quantity of the variable milling.

Response: This unit should have been SY as opposed to SF as noted on the Plans and Invitation to Bid. Sheet 06-0001 and the Bid Form within the Invitation to Bid has been revised and is attached.

PLAN CHANGES

Replace plan sheet 06-0001 with the revised plan sheet with revision date 9/21/17.

BID DOCUMENT CHANGES

Replace the Bid Form with the revised Bid Form with revision date 9/21/17.

All other terms & conditions remain unchanged.

End of Addendum #1